

SPECIFICATIONS SECTION 07726

DUAL LID ICC LISTED HEAT AND SMOKE VENTS

PART 1 – GENERAL

1.01 SUMMARY

- A. Section includes:
 - 1. Prefabricated ICC Listed dual lid heat and smoke vents, with Sky-Tough™ UL 972 Impact resistant domed lids, curbs, hardware and counter flashing.
 - 2. Prefabricated ICC Listed dual metal lid heat and smoke vents, curbs, hardware and counter flashing.

- B. Related Sections:
 - 1. Section 07510 – Built-up Bituminous Roofing
 - 2. Section 07525 – Modified Sheet Roofing.
 - 3. Section 07360 – Single Ply Membrane Roofing
 - 4. Section 07600 – Flashing and Sheet Metal Trim
 - 5. Section 07610 – Sheet Metal Roofing

1.02 REFERENCES

- A. Aluminum Association (AA)
 - 1. Specifications for Aluminum Structures.

- B. American Architectural Manufacturers Association (AAMA)
 - 1. AAMA 1600/IS7, Skylight Standard
 - 2. AAMA Skylight Installation Manual
 - 3. AAMA 1505.1-87, Voluntary Standard Uniform Load Test Procedure for Plastic Glazing Skylights by Uniform Static Air Pressure Difference.

- C. American Society for Testing and Materials (ASTM)
 - 1. ASTM D4802 Specification for Poly (Methyl Methacrylate) Acrylic Plastic Sheet
 - 2. ASTM E331 Test Method for Water Penetration of Exterior Windows, Curtain Walls and doors by Static Air Pressure Difference.
 - 3. ASTM A-463 Specification for Steel Sheet, Cold Rolled, Aluminum Coated, Type 1 or Type 2.
 - 4. ASTM A-653 Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc Alloy Coated by the Hot Dip process.
 - 5. ASTM A 792 Specification for Steel Sheet, Fifty-Five Percent Aluminum-Zinc Alloy coated by the Hot Dip Process.

- D. National Roofing Contractors Association (NRCA)
 - 1. Roofing and Waterproofing Manual.

SECTION 07726

DUAL LID HEAT AND SMOKE VENTS

- E. Underwriters Laboratory (UL)
 - 1. UL 972 Standard for Burglar and Impact Resistant Glazing
- F. National Fire Protection Association (NFPA)
 - 1. NFPA 204 Standard for Heat and Smoke Vents
- G. American Welding Society (AWS)
 - 1. AWS D1.1 Structural Welding Code
- H. International Fire Code (IFC)
 - 1. Section 910 – Heat and Smoke Vents

1.03 PERFORMANCE REQUIREMENTS

- A. Sky-Tough glazed smoke vents shall conform to the recommendations of AAMA 1600/IS7
- B. Smoke Vents (Sky-Tough glazed or Metal Lids) shall operate automatically when subjected to heat at the temperature of the fusible link. .
- C. Smoke Vents shall be Listed by ICC Evaluation Services (ICC Report #1004)
- D. Glazing material shall be UL 972 Listed for Impact resistance.
- E. Glazing Material shall satisfy OSHA Fall Protection Standards.
- F. Smoke Vents shall operate automatically by activation of a UL Listed or FM Approved fusible link. Link temperature as required by the Authority having Jurisdiction.
- G. Units shall comply with the specific requirements of the Authority Having Jurisdiction (AHJ) and may include any of the following:
 - 1. Exterior and/or interior manual release.
 - 2. Activation by smoke detector
 - 3. Activation by sprinkler flow valve
 - 4. Activation by remote manual control utilizing electro-thermal links (ETL)
 - 5. Activation by a re-settable ETL (McCabe Link)
 - 6. Ganged vent operation.

1.04 SUBMITTALS

- A. Product data: Submit manufacturer's product data and shop drawings.
- B. Provide test reports indicating the smoke vent will open against a 10 psf positive external load.
- C. Submit copy of ICC ES Report indicating ICC Evaluation Services approval of smoke vent.

1.05 WARRANTY

- A. Smoke Vent Warranty: Provide written warranty by the manufacturer, agreeing to repair or replace work that exhibits defects in materials or workmanship.
 - 1. Warranty period: 5 years from date of installation.

SECTION 07726

DUAL LID HEAT AND SMOKE VENTS

PART 2 PRODUCTS

2.01 PLASTIC DOMED DUAL LID HEAT AND SMOKE VENTS

- A. Manufacturers: Subject to compliance with requirements. Approved manufacturers are:
 - 1. ACRALIGHT International Skylights, 1831 S. Ritchey Street, Santa Ana, CA 92705 (800 325-5355) (Fax: 714 258-7033) www.acralight.com
 - 2. Or Approved equal. (Prior approval must be obtained 10 days prior to bid date)
- B. Manufactured units: ICC Listed Dual-Lid, with UL or FM approved fusible link, link temperature as required.
 - 1. Finish: Manufacturer's standard mill finish aluminum or galvanized steel (specifier note – optional prime finish).
 - 2. ACRALIGHT International Model Number S-SV2D (for galvanized steel) or A-SV2D (for Aluminum).
 - 3. Inside curb dimension to be 48" x 96".
 - 4. Plastic Drop-out smoke vents are not permitted
- C. Lids: Sky-Tough UL 972 Listed white glazing outer dome, (optional clear inner dome) in aluminum or galvanized steel frame. Designed to withstand a 30 psf uplift load in the closed position. Units shall be furnished with an interior and/or exterior manual release handle. When released, lids shall open against a 10 psf positive external load.
- D. Curbs: curb mounted (CM) or self flashing curbs to be manufacturer's standard aluminum or galvanized steel, curb height as noted on drawings.
- E. Steel Security Bars: Optional steel burglar bars by ACRALIGHT International shall be ½" steel bars welded and assembled into a 1 ½" x 1 ½" x 1/8" steel angle frame. ACRALIGHT International (800 325-4355) www.acralight.com

2.02 SMOKE VENTS WITH DUAL METAL LIDS

- A. Manufacturers: Subject to compliance with requirements. Approved manufacturers are:
 - 1. ACRALIGHT International Skylights, 1831 S. Ritchey Street, Santa Ana, CA 92705 (800 325-4355) (Fax: 714 258-7033) www.acralight.com
 - 2. Or Approved equal. (Prior approval must be obtained 10 days prior to bid date)
- B. Manufactured units: ICC Listed Dual-Lid, with UL or FM approved fusible link, link temperature as required.
 - 1. Finish: Manufacturer's standard mill finish aluminum or galvanized steel (specifier note – optional prime finish).
 - 2. ACRALIGHT International Model Number S-SV2D-ML (for galvanized steel) or A-SV2D-ML (for aluminum)
 - 3. Inside curb dimension to be 48" x 96".

SECTION 07726

DUAL LID HEAT AND SMOKE VENTS

- C. Lids: Aluminum or galvanized steel lids with 1" rigid insulation and interior metal liner. Designed to withstand a 30 psf uplift load in the closed position. Units shall be furnished with an interior and/or exterior manual release handle. When released, lids shall open against a 10 psf positive external load.
- D. Curbs: curb mounted or self flashing curbs to be manufacturer's standard aluminum or galvanized steel, 12" high (or as noted on drawings)
- E. Steel Security Bars: Optional steel burglar bars by ACRALIGHT International shall be ½" steel bars welded and assembled into a 1 ½" x 1 ½" x 1/8" steel angle frame. ACRALIGHT International (800 325-4355) www.acralight.com

2.03 FABRICATION

- A. Fabricate free of visual distortions and defects. Weld corners and joints.
- B. All fasteners and hardware shall be corrosive resistant Stainless Steel.
- C. Provide for removal of condensation.
- D. Provide a weather tight assembly.

2.04 DELIVERY, STORAGE AND HANDLING

- A. Handle, deliver and store in manufacturer's original packaging, following the manufacturer's recommendations. Store in a manner as to prevent damage.
- B. Exercise caution when hoisting units to the roof so as not to damage the release mechanism.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install completely assembled smoke vents with curbs in accordance with manufacturer's instructions. Coordinate roof membrane installation requirements specified in other Sections.
- B. Smoke Vent curbs bearing on roof deck:
 - 1. Set units in place and secure curb flange to steel roof deck by self tapping non-corrosive screw fasteners, spaced at a maximum of 12" on center, staggered.
- C. Apply bituminous paint on metal surfaces of units in contact with cementitious material and dissimilar metals.
- D. After installation, remove shipping screws and test vents to insure that vents operate as intended.

3.02 INSPECTION AND MAINTENANCE

- A. Inspect and maintain smoke vents in accordance with the requirements of the NFPA 204 Standard for Heat and Smoke Vents.

END OF SECTION